

STATEMENT

This is to certify that on board

MV: SK HERMANN HELMS
MMSI: 211202760

FM 200 installation(s)

as per enclosed specifications


have been inspected, repaired and refilled where necessary

and sealed with date-labels,

in the port of: Cuxhaven

We guarantee that above mentioned equipment has been left in good working condition on the date of

21 December 2015


Survitec Service and Distribution
Norman Böden

Date 21 December 2015	Name of ship/unit SK HERMANN HELMS	IMO Number	Flag Germany
---------------------------------	--	------------	------------------------

Technical description

No.	Text	Value
1	Manufacturer	Seafire
2	Number of main cylinders	1 x 138 kg; 4 x 2 kg FM
3	Main cylinders capacity (each)	
4	Number of pilot cylinder	
5	Pilot cylinder capacity (each)	
6	Number of distribution lines	5
7	Oldest cylinder pressure date	Mai. 04
8	Protected space(s)	Maschine;Gen.-STb; Gen.-Bb;E-Schrank;Tochterboot "BIENE"
9	Date flexible hoses fitted/renewed	

No.	Description	Carried out	Not carried out	Not applicable	Comment
1	Release controls and distribution valves secured to prevent accidental discharge	X			
2	Cylinders checked by weighing and nitrogen pressure		X		
3	Contents in main cylinders checked by liquid level indicator and, or nitrogen pressure	X			
4	contents of pilot cylinders checked			X	
5	All cylinders valves visually inspected	X			
6	All cylinder clamps and connections checked for tightness	X			
7	Manifold visually inspected	X			
8	Manifold tested for leachage, by applying dry work air		X		
9	Main valve and distribution valves visually inspected	X			
10	Main valve and distribution valves tested for operation		X		
11	Time delay devices tested for correct setting*			X	
12	Remote release system visually inspected	X			
13	Cylinder actuator system tested				
14	Discharge lines and distribution valves inspected and tested for leachage and blockage			X	
15	Manual pull cables, Pulleys, gang releases tested, serviced and tightened/adjusted as necessary	X			
16	Release stations visually inspected	X			
17	Warning alarms (audible/vsual) tested	X			
18	Fan stop tested			X	
19	10% of cylinders and pilot cylinder/s pressure tested every 10 year		X		
20	Discharge nozzles and pipework visually inspected	X			
21	All doors, hinges and locks inspected *	X			
22	All instruction and warning signs on installation inspected	X			
23	All flexible hoses renewed and check valves in manifold visually inspected every 10 years	X			
24	System activated	X			
25	Inspection date tags attached	X			

* If fitted as part of the system.



SURVITEC SERVICE & DISTRIBUTION
 Norman Böden

Handelsregister:
 Hamburg HRB 20840
 USt. IdNr.: DE 21240719
 Geschäftsführer:
 Greg Russell Allan
 Brian Stringer
 Christopher Bates
 Christopher Taylor



Survitec Group
 Hermann Helms
 Ship's officials
 Westkai 50 / Störstr. 1, D-27572 Bremerhaven, Germany
 Tel: +49 (0)471 982 17-0 / Fax: +49 (0)471 982 17-20 / Email: brian.stringer@survitecgroup.com
 www.survitecgroup.com