

CERTIFICATE

Ship: LOTS 031 GOLJE Call Sign: SKGM

Home Port: NORRKÖPING

CO₂ FIRE EXTINGUISHING SYSTEM

We hereby certify that the TEMPUS PNEM FIRE EXTINGUISHING SYSTEM for ENGINEER ROOM this day have been checked on board the LOTS 031 GOLJE in Iggesund.

The Plant have been left in Good and Working Condition.

3 pcs Cylinders 40 lit.

Charge: 26 kg CO₂.

Total quantity CO₂: 78 kg.

Cylinder pressuretested 2023.

Manually operated release system.

Leaking supervision: Gauge and Pressure Switches.

Fire detection central: DAFO.

Fire Alarm: 2 pcs Smokedetectors.

Type of certificate: Total System Control (see reverse side)

Next service 2025-05

Stockholm 24-05-06

Presto AB

Hans Larsson

Hans Larsson



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584

Type of certificate

Level Control, includes checking of (when applicable):

- Content of cylinders
- Gauges
- Control units
- Warning alarms
- Fanstops
- Pressure switches, supervision
- Initiators
- Pipes and nozzles, air check, blow through
- Pilotcylinders
- Mechanical fitting
- Signs
- Rust damages etc

Total System Control, includes checking of (when applicable):

- Content of cylinders
- Gauges
- Release wires, gang releasers
- Main valves
- Warning alarms
- Fanstops
- Pressureswitches, supervision
- Pilotcylinders
- Initiators
- Manifolder and connections
- Pipes and nozzles, air check, blow through
- Release function test
- Control units
- Mechanical fitting
- Signs
- Rust damages etc
- CO₂-room fan



Presto AB
Gävlegatan 22
113 30 Stockholm

Växel
+46 10-452 00 00

E-mail
marineservice@presto.se

Hemsida
www.presto.se

Org.nr
556112-0584